

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY **REGION 10**

1200 Sixth Avenue Seattle, Washington 98101

January 10, 1994

Reply to

Attn of: WD-133

CERTIFIED MAIL -RETURN RECEIPT REQUESTED

Melvin Sampson Eagles Stop n Save 50 West Wapato Road Wapato, Washington 98951

Underground Storage Tank Program

Dear Mr. Sampson:

It has come to the attention of the U.S. Environmental Protection Agency (EPA) Region 10 that you are the owner or operator of an underground storage tank(s) located at the following address: Stop n Save, 50 West Wapato Road, Wapato, Washington 98951. Code of Federal Regulations (40 CFR §280.22) owners and operators of underground storage tanks (UST) are required to submit notification of the existence of these tanks to the U.S. EPA. Tanks on Indian lands are not exempt from the notification requirement. A check of our records has indicated that you have not yet fulfilled this requirement. Be advised that there is a possible \$10,000 fine for each tank for non-notification.

If your UST system is registered with the state, technically you are in compliance. However, you must still register the UST with the U.S. EPA Region 10. You may do so by completing the enclosed form and mailing it to the following by February 18, 1994:

> Katherine M. Holt U.S. EPA Region 10 1200 Sixth Avenue, WD-133 Seattle, WA 98101

If you have questions about notification or any other UST requirements, please call me at (206) 553-2580 or Geoff Keeler at (206) 553-1089.

Katherine M. Llott Katherine M. Holt


UST Program


Enclosures

- Notification form 1.
- 40 CFR §280 2.
- Musts for USTs

Jannine Jennings, Tribal UST Coordinator cc: Todd Bender, EPA-Region 10 Enforcement Coordinator Geoff Keeler, EPA-Circuit Rider







P15 245 219

AN EQUAL OPPORTUNITY EMPLOYER

RETURN

RECEIPT REQUESTED

SEATTLE, WA 98101 WW-133

1200 SIXTH AVENUE

ENVIRONMENTAL PROTECTION AGENCY

CN

U.S.PUSIA 10

CERTIFIED